

Thru mail
CREW to 6 PM m
23.12.2013

:: TANTRANSCO ::

FROM

Er. R.V.Sundararaman,B.E, M.A, F.I.E.,
Chief Engineer/ Transmission
6th Floor, NPKRR Maaligai,
144, Anna Salai,
Chennai – 600 002.

TO

**M/s Chennai Radha Engineering
Works (P) Limited,**
No. 40,Sapthagiri Colony,
(K.R.Layout),
Jafferkhanpet,
Chennai- 600 083

Lr.No. CE/TR/SE/TR III/EEP/AEE4/LOA No. 2460/D. 83 /13 Dt:23 .12.13

Dear Sirs,

Sub: Electricity – LOA.2460 – Establishment of Karamadai 230/110KV Substation in Coimbatore Region-Carryingout the balance works on turnkey basis-Work under execution by M/s Chennai Radha Engineering Works (P) Ltd., Chennai – vendor and GTP approval for supply of various sizes of cables and battery-Regarding.

Ref: 1. LOA 2460 Dt. 23.11.2013
2.Your Lrs. dt. 12.12.13 & 21.12.13.

* * * *

Referring to the above, the drawings, GTP and type test reports furnished for the following items from the respective suppliers are found to be generally in order.

Sl No	Description	Name of Supplier
1.	Armoured copper control cable	M/s Suyog Electricals Ltd., Vadodara.
	a) 2 x 2.5 sq. mm.	
	b) 4 x 2.5 sq. mm.	
	c) 8 x 2.5 sq. mm.	
	d) 14 x 2.5 sq. mm.	
	e) 20 x 2.5 sq. mm.	
	f) 4 x 4 sq. mm.	
	g) 8 x 4 sq. mm.	
2	Battery 220V/300AH	M/s Exide Industries Ltd., Kolkatta

You are requested to submit 6 sets of GTP and drawings and get approval. You are also requested to offer inspection for the above equipments at the earliest.

This letter is issued without prejudice to the other terms and condition of the contract and does not absolve you of your responsibility from fulfilling the contractual obligations of the subject LOA.

Sd. *****

**For Chief Engineer/Transmission
SE/TR-III**

Copy to Chief Engineer/ Trans. Project I & II. for information.

Copy to SE/GCC/ Coimbatore – For information. He is requested to closely monitor and to coordinate with the contractor so as to commission the substation at the earliest. Field officials may also be instructed in this regard.